

# BPIR Declaration

FYRESAFE™ SLIDING FIRE DOOR

## DESIGNATED BUILDING PRODUCT

Class 2

## DECLARATION

ARA Group NZ Limited, trading as Metalbilt has provided this declaration to satisfy the provisions of Schedule 1(d) of the Building (Building Product Information Requirements) Regulations 2022.

## PRODUCT SYSTEM

Fyresafe™ Sliding Fire Door

System identifier: Fyresafe™ Sliding Fire Door

## DESCRIPTION

Fyresafe™ Sliding Fire Doors are a commercial / industrial sliding door product specifically designed to provide protection from a fire emergency.

- Lightweight refracting core
- Clad in galvanised steel sheeting
- Capped with steel channels
- Doors can be single leaf or bi-parting

A wide range of sizing is available up to a maximum width of 6 metres and maximum height of 5 metres.

Fire rated for masonry walls to provide up to -/240/30 FRR or up to -/60/30 in a specially modified timber stud wall.

Doors can be free to manually slide open and closed or set to 'always open' or 'self-closing' modes (for smaller doors).

May be activated by fusible link or by alarm signal.

For further information, go to <https://manufacture.aragroup.co.nz/products/fyresafe-sliding-fire-doors>

# BPIR Declaration

## SCOPE OF USE

Fyresafe™ Sliding Fire Doors are suitable for internal and external use in commercial and industrial buildings to compartmentalise large areas of a building into smaller units greatly reducing the spread of fire. Preferred fire door when hinged doors are impractical.

Not suitable to provide natural light or ventilation.

Fyresafe™ provide up to 30 minutes insulation.

## CONDITIONS OF USE

Fyresafe™ Sliding Fire Doors must be installed by a competent and experienced commercial fire door installer, as per the installation instructions.

Operating instructions must be followed for correct use.

Openings must be designed with minimum requirements given in the technical drawings.

Fyresafe™ are to be used where fire ratings are a requirement.

## RELEVANT BUILDING CODE CLAUSES

**B1 Structure** — B1.3.1, B1.3.2, B1.3.3 (a, b, h, j), B1.3.4

**B2 Durability** — B2.3.1 (b, c)

**C3 Fire affecting areas beyond the fire source** — C3.5, C3.6, C3.7

**F2 Hazardous building materials** — F2.3.1

**H1 Energy efficiency** — H1.3.1 (a, b), H1.3.2E

## CONTRIBUTIONS TO COMPLIANCE

### Structure

These doors are manufactured from strong, durable materials. Account has been taken for relevant physical conditions, including self-weight, imposed gravity loads and impact to ensure the doors can withstand these forces without being compromised.

### Durability

Fyresafe™ have a durability of at least 5 years under normal use and correct maintenance conditions.

### Fire affecting areas beyond the fire source

Fyresafe™ Sliding Fire Doors are fire rated for masonry walls to provide up to -/240/30 FRR or up to -/60/30 in a specially modified timber stud wall.

### Hazardous Building Materials

Fyresafe™ are safe when handled

## SUPPORTING DOCUMENTATION

### Fyresafe™ Sliding Fire Door Datasheet

<https://manufacture.aragroup.co.nz/wp-content/uploads/2022/05/Metalbilt-Fyresafe-™-Sliding-Fire-Doors-Marketing-Flyer.pdf>

For further information supporting Fyresafe™ Sliding Fire Door claims refer to our website.

# BPIR Declaration

## CONTACT DETAILS

|  |   |
|--|---|
| Manufacture location                   | New Zealand   |
| Legal and trading name of manufacturer | ARA Group NZ Limited trading as Metalbilt   |
| Manufacturer address for service       | 26 Timothy Place Auckland 1026  |
| Manufacturer website                   | <a href="https://manufacture.aragroup.co.nz/">https://manufacture.aragroup.co.nz/</a> |
| Manufacturer email                     | info.nz@metalbilt.co.nz   |
| Manufacturer phone number              | 0800 638 252  |
| Manufacturer NZBN                      | 94290 4244 2738   |

## RESPONSIBLE PERSONS

As the responsible person as set out in Regulation 3, I confirm that the information supplied in this declaration is based on information supplied to the company as well as the company's own processes and is therefore to the best of my knowledge, correct.

I can also confirm that Security Roller Grille is not subject to a warning on ban under s26 of the Building Act.

Signed for and on behalf of ARA Group NZ Limited trading as Metalbilt:

---

**ARA GROUP NZ LIMITED TRADING AS METALBILT**  
26 Timothy Place Auckland 1026 New Zealand  
0800 638 252 | <https://manufacture.aragroup.co.nz/>